



Project Description:

REVISIONS:

1. _____

2. _____

3. _____

4. _____

5. _____

SHEET No.

E1.2

POWER PLAN EAST



1. CONNECT EXIT AND EMERGENCY LIGHTING TO NEAREST UNSWITCHED CIRCUIT.
2. THE MINIMUM CONDUIT SIZE SHALL BE 1/2". THE CONDUIT SHALL BE SIZED FOR 40 % FILL OR LESS, AS REQUIRED BY PREVAILING CODE.
3. ALL ABOVE SLAB CONDUIT SHALL BE EMT.
4. ALL BELOW SLAB CONDUIT SHALL BE PVC.
5. THE MINIMUM CONDUCTOR SIZE SHALL BE #12 COPPER.
6. ALL ABOVE SLAB CONDUCTORS SHALL BE COPPER THIN.
7. ALL BELOW SLAB CONDUCTORS SHALL BE COPPER THWN, EHMW.
8. ALL SWITCHING, EXIT SIGNS, AND EMERGENCY LIGHTS IN THE AUDITORIUM TO HAVE WIRING GUARD PROTECTION.



SEE SHEET ES1
FOR CONTINUATION